

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Report No.: VNS/SAN2025-26/0001


Date: 29.04.2025


It is certified that an inspection team headed by Er. Shatrughan Kumar, Assistant Engineer (Name of Officers with designation) from U.P. Jal Nigam (Rural), Varanasi inspected the St. Josheph's School, Majhawa, Sindhora, varanasi-221208 (Name & Address of the school) on 27.04.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no C/VNS/APR25/000385 dated 25.04.2025 of Regional Water Analysis Laboratory, U.P. Jal Nigam (Rural) (An NABL Accredited Laboratory), Ganga Pollution Control Unit Campus, Bhagwanpur, Lanka, Varanasi- 221005 certified that the St. Josheph's School, Majhawa, Sindhora, varanasi (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 Year only.

Signature with seal


 Name : Er. Shatrughan Kumar
 Designation : Assistant Engineer
 Name & Address of the Office/Department : U. P. Jal Nigam (Rural), Varanasi
 Shatrughan Kumar
 Assistant Engineer
 Vith G.D., U.P.J.N. (Gramin)
 Varanasi


 Principal
 St. Josheph's School,
 Majhawa, Sindhora, varanasi-221208.
 (Name & Address of School)


 Manager
 St. Joseph's School
 Varanasi



Regional Water Analysis Laboratory

(An NABL Accredited Laboratory)

Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005

Report No.: C/VNS/2023/000385

Date: 24.04.2025

No. of Pages: 1

Customer Details

Office Name and Address

St. Joseph's School, (Majhawa), Sindhora, Varanasi-221708

Ref. Letter No. & Date

NA

Date: 23.04.2025

Basic Details of Sample

District	Varanasi	Block	Pindra
Gram Panchayat	Majhawa	Village	Majhawa
Habitation	NA	Location	Sindhora, Varanasi
Water Source	RO Water	Sample Code	VNS/APR25/0385
Quantity of Sample	1000 mL (Normal)	Sampling date	24.04.2025
Sample Received Date	24.04.2025	S. collected by	Mr. Devrishi
Sampling Method Used	NA	Sample Depositor	Mr. Devrishi
Analysis Start Date	25.04.2025	Analysis Completion date	25.04.2025

Temperature: 25.8°C, Humidity: 50%

Test Result

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.12	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
2	Turbidity (NTU)	0.99	1	5	IS 3025 (Part 10): 2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	44.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	BDL	250	1000	IS 3025 (Part 32): 2019 (Archimetric method)
5	Total Alkalinity, (as CaCO ₃) mg/l	11.33	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	BDL	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Calcium (as Ca), mg/l	BDL	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
8	Magnesium (as Mg), mg/l	BDL	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO ₄), mg/l	1.52	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
10	Nitrate (as NO ₃), mg/l	BDL	45	No relaxation	APHA 24rd Edition -4500-NO ₃ Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	BDL	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion Selective Electrode Method): 2023
12	Iron (as Fe), mg/l	BDL	1.0	No relaxation	APHA 24rd Edition -4500-Fe Method B (Phenanthroline Method): 2023

All These parameters are under NABL Scope, BDL: Below Detection Limit, NA: Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.

3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.

4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.

5. Parameters above Permissible Limit are written in bold.

6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.

7. Sample is not Collected by Lab.

ABHAY KUMAR PANDEY
(Report prepared by)VIVEK KUMAR
(Report Reviewed by)VIVEK KUMAR
(Report Approved by)

Laboratory Contact detail:

Email: arounjn@gmail.com

Mobile No: 8400202287

*****END OF THE ANALYSIS REPORT*****

Manager
St. Joseph's School
VaranasiPrincipal
St. Joseph's School
Majhawa, Sindhora, Varanasi